

No: 2017D0305



Product Name	Fiberglass mesh			Report Date	Mar.14 th ,2017	
Specification	125g/m ² , 10x10mm			Sample Qty	3 m ²	
No.	ITEM	UNIT	STANDARD	RESULT	CONCLUSION	
1	Tensile strength	Warp	N/50mm	750N	1221	Up to standard
		Weft				
2	Alkali resistance	%	≥50%	56%	Up to standard	
3	Content of resin %	g/m ²	≥ 13%	14%	Up to standard	
4	Weight per unit area	g/m ²	≥ 115	125	Up to standard	

STANDARD BASIS : JG 149-2003

REPORT CONCLUSION : In accordance with industrial standard